RIGHTS-OF-WAY AND EASEMENTS

CUSTOMER PROVIDED RIGHTS-OF-WAY AND EASEMENTS

- 1. Service provider shall be granted all rights-of-way and easements in a form acceptable to and at no cost to company for the erection, maintenance, repair, replacement, and removal for use of all distribution facilities necessary or convenient for the supplying of electric service to the customer. It is the responsibility of the customer to provide such easements and rights-of-way.
- 2. The customer will also provide free, safe, and unimpaired access at reasonable times to the premises of the customer for the purpose of reading meters, testing, repairing, removing or exchanging any or all equipment belonging to company. Service provider may discontinue service after proper notice issued, if violations of this right of free, safe, and unimpaired access continues to occur.



EASEMENT LINE (X BY X OR Y)

- X = 10 FT. FOR SECONDARY PEDESTAL, J10 & J30 (SEE SR-209, PAGE 4 & 5).
- X = 10 FT. FOR SINGLE-PHASE TRANSFORMER & J1 CABINET (SEE SR-209, PAGE 3 & 6).
- X = 10 FT. FOR J2 AND F2 CABINET (SEE SR-234 OR SR-242).
- X = 15 FT. FOR PMH/PME/VISTA SWITCHGEAR (SEE SR-240 AND SR-232).
- X = 15 FT. FOR THREE-PHASE TRANSFORMER (SEE SR-233).
- X = 15 FT. FOR THREE-PHASE CAPACITOR (SEE SR-233 AND SR-241).
- X = 15 FT. FOR THREE-PHASE J-6. (SEE SR-236).
- Y = 15 FT. FOR THE WIDTH OF PULL BOX (SEE SR-225).
- X = 20 FT. FOR THE LENGTH OF PULL BOX (SEE SR-225).
 - 10 FT. STRIP FOR UNDERGROUND PRIMARY, SECONDARY AND SERVICES.
 - 10 FT. STRIP FOR UNDERGROUND 46kV.
 - 18 FT. STRIP FOR OVERHEAD DISTRIBUTION POLE LINES.

"VARIES" STRIP FOR OVERHEAD 46KV AND 138KV POLE LINES.

NOTE: REFER TO COMPANY ISSUED CONSTRUCTION DRAWING FOR PROJECT SPECIFIC EASEMENTS AND REQUIRED ACCESS OR ACCESS EASEMENTS.

		INITIATED BY	JKC	REVISION NO.	5	SR-108
TEP'	UniSourceEnergy			ESR COMM.	10-24	
Tucson Electric Power	SERVIČEŠ Santa Cruz County	ESR COMM.	12-15	EFFECTIVE DATE	10-24	Pg. 1 of 3

RIGHTS-OF-WAY AND EASEMENTS

Registered Land Surveyor Information

This section outlines the requirements which the professional land surveyor must consider when preparing a legal description and exhibit drawing for a proposed easement on behalf of their client, our customer. These requirements are provided to achieve an optimum degree of uniformity of product submitted to the Company.

- 1. Legal description will be prepared and stamped by a Professional Land Surveyor in good standing registered in the State of Arizona.
- 2. The submitted legal description for an easement to be granted shall meet the criteria set forth in Section 14 of the PDF titled, "Arizona Boundary Survey Minimum Standards," available on the Arizona Board of Technical Registration website. Page size must be 8.50 x 11.00 inches in portrait orientation.
- 3. An exhibit drawing must accompany the legal description to visually support the written narrative (see requirements below).

Legal Description

Caption

- 1. Indicate use in a general manner, such as: "An electric easement within a portion of...." DO NOT state specific use (i.e., particular type of equipment nor its use as overhead or underground).
- 2. State geographic location by:
 - a. Reference to a government land division within the U.S. Public Land Survey System, a Land Grant, a Reservation, a Homestead, etc.
 - b. Lot or parcel (number or letter), block or tract within a county recorded subdivision identifying said County Recorder's Office and the recordation number of said subdivision.
 - c. Citation of the recorded deed of the parcel of land the easement will encumber.

Body

- 1. A clearly stated basis of bearing, referencing two existing, physically described controlling monuments.
- 2. Sufficient data to enable a mathematical verification of the easement being inscribed within the property being encumbered.
- 3. Where described, curve segments shall contain sufficient information to allow verification of the data by mathematical analysis. Curves are presumed to be circular and tangent. All other non-tangent and/or non-circular curves must be noted in the description.
- 4. Identify and note any existing, recorded electric easement(s) which is/are intended to join with the new easement as a continuous, uninterrupted land right.
- 5. Report the total area of the easement(s) in square feet when less than an acre (rounded to the nearest foot) or in acres when area exceeds 43,560 square feet (three places to right of the decimal).



		INITIATED BY	JKC 12-15	REVISION NO.	4	SR-108
	UniSourceEnergy			ESR COMM.	4-23	
wer	SERVICES Santa Cruz County	ESR COMM.		EFFECTIVE DATE	4-23	Pg. 2 of 3

RIGHTS-OF-WAY AND EASEMENTS

Exhibit Drawing

- 1. Page size to be 8.50 x 11.00 inches (ANSI A).
- 2. Title block must state the township, range, section(s) and meridian of the easement location.
- 3. A north arrow.
- 4. If applicable, a line table and/or curve data will be shown.
- 5. Note assessor's parcel number (APN) of affected parcel.
- 6. The county recording number of the deed of the underlying parcel.
- 7. Boundary lines shown of all parcels affected by the easement.
- 8. Depict existing, recorded electric easement(s) which is/are intended to join with the new easement.

Deliverables

In an effort to operate and maintain a geographic information system (GIS) for both corporate land rights and facility mapping purposes, the Company now requires delivery of specific electronic files by the customer.

- 1. An original, stamped paper final draft which meets County recording requirements based on A.R.S. 11-480.
- CAD file of the results of survey drawing (AutoCAD 2005 or newer) (.DWG or .DXF) geo-referenced to the minimal standard of Arizona State Plane Grid Coordinate System NAD83/HARN92, AZ Central Zone, State Plane Int'l Feet. Newer published National Spatial Reference System (NSRS) datums by the NGS such as NAD83(CORS96), NAD83(2007) and NAD83(2011) are acceptable. Please note as part of the required metadata file.
- 3. Metadata text file (include projection, datum, project name, Company/Firm, name of preparer and date).

Resources

Below are a resources for geodetic control for GPS RTK localization of an easement survey:

- PCDOT/TDOT geodetic control points found at http://gis.pima.gov/maps/mapguide/
- NOAA NGS Survey Marks and Datasheets site http://www.ngs.noaa.gov/datasheets/
- Santa Cruz County (AZ) Public Works Department, a comprehensive control survey by CPE Consultants LLC (March 2014) titled, <u>"Santa Cruz County GIS Control Monument Survey"</u>
- NOAA NGS OPUS online positioning solution of a GPS static session http://www.ngs.noaa.gov/OPUS/



	UniSourceEnergy SERVICES	INITIATED BY	EKD 9-19	REVISION NO.	1	SR-108	
				ESR COMM.	4-23		
wer	JER VILED SANTA CRUZ COUNTY	ESR COMM.		EFFECTIVE DATE	4-23	Pg. 3 of 3	3