

## USE: Protect Company Equipment from

## **EQUIPMENT ENCLOSURE CABINETS**







## NOTES:

- CUSTOMER SHALL INSTALL CABINET AT THE REQUEST OF SERVICE PROVIDER FOR PROTECTION OF COMPANY EQUIPMENT. FOR SERVICE METER PANELS INSTALLED IN PUBLIC ROW OR COMMON PUBLIC AREAS, INSTALL PER SR-409.
- 2. EQUIPMENT ENCLOSURE CABINETS SHALL BE CONSTRUCTED OF STEEL OF NOT LESS THAN NO. 16 MSG, PROTECTED AGAINST CORROSION BOTH INSIDE AND OUTSIDE. THEY SHALL SHED WATER, BUT ARE NOT REQUIRED TO BE RAIN-TIGHT.
- 3. EQUIPMENT ENCLOSURE CABINET DOORS SHALL BE HINGED AND PROVIDED WITH A LATCHING DEVICE THAT WILL ACCOMMODATE A SERVICE PROVIDER PADLOCK. HINGES SHALL BE ON THE SIDES SO THAT MAXIMUM WORKING SPACE IS AVAILABLE. SINGLE OR DOUBLE DOORS ARE APPROVED.
- NOT SUITABLE FOR METER POSTS (SR-408, PG. 5), SAFETY SOCKET BOX (SR-410, 480V INSTALLATIONS). CONSULT DESIGN SERVICES FOR INSTALLATION OF THESE DEVICES.
- SUGGESTED PART NUMBERS & MANUFACTURERS:

P/N: EP222415 T. A. CAID & SONS GENERAL SHEET METAL 2049 W. HIGHWAY DRIVE TUCSON, AZ 85705



P/N: 514U7946 METER DEVICES CO., INC. BROOKS UTILITY PRODUCTS 43045 W. NINE MILE ROAD NOVI, MI 48375

TEP)	U
Tucson Electric Power	

UniSourceEnergy
SERVICES
SANTA CRUZ COUNTY

INITIATED BY	SC	REVISION NO.	8
TIVITIA TES ST		ESR COMM.	7-19
ESR COMM.	2-80	EFFECTIVE DATE	7-19

SR-420 Pg. 1 of 1