

## EQUIPMENT ENCLOSURE CABINETS







## NOTES:

**USE: Protect Company** 

- 1. CUSTOMER SHALL INSTALL CABINET AT THE REQUEST OF SERVICE PROVIDER FOR PROTECTION OF COMPANY EQUIPMENT. FOR SERVICE METER PANELS INSTALLED IN PUBLIC ROW OR COMMON PUBLIC AREAS, INSTALL PER SR-409.
- 2. EQUIPMENT ENCLOSURE CABINETS SHALL BE CONSTRUCTED OF STEEL OF NOT LESS THAN NO. 16 MSG, PROTECTED AGAINST CORROSION BOTH INSIDE AND OUTSIDE. THEY SHALL SHED WATER, BUT ARE NOT REQUIRED TO BE RAIN-TIGHT.
- 3. EQUIPMENT ENCLOSURE CABINET DOORS SHALL BE HINGED AND PROVIDED WITH A LATCHING DEVICE THAT WILL ACCOMMODATE A SERVICE PROVIDER PADLOCK. HINGES SHALL BE ON THE SIDES SO THAT MAXIMUM WORKING SPACE IS AVAILABLE. SINGLE OR DOUBLE DOORS ARE APPROVED.
- NOT SUITABLE FOR METER POSTS (SR-408, PG. 5), SAFETY SOCKET BOX (SR-410, 480V INSTALLATIONS). CONSULT DESIGN SERVICES FOR INSTALLATION OF THESE DEVICES.
- 5. SUGGESTED PART NUMBERS & MANUFACTURERS:

P/N: EP222415 T. A. CAID & SONS GENERAL SHEET METAL 2049 W. HIGHWAY DRIVE TUCSON, AZ 85705



P/N: 514U7946 METER DEVICES CO., INC. BROOKS UTILITY PRODUCTS 43045 W. NINE MILE ROAD NOVI, MI 48375

IniCoupocTr	ongy INITIATED BY	SC	REVISION NO.	8	SR-420
<b>TEP</b> UniSourceEn	RVICES ESP. COMM		ESR COMM.	7-19	D . 1 C1
Tucson Electric Power SANTA CRU	ESR COMM.	2-80	EFFECTIVE DATE	7-19	Pg. I of I